

BLIS.R26312 Caulking and Sealants

Page Bottom

Caulking and Sealants

See General Information for Caulking and Sealants

SAINT-GOBAIN PERFORMANCE PLASTICS CORP

R26312

1 SEALANTS PARK GRANVILLE, NY 12832 USA

Sealant material designated Green Glue "NoiseProofing Compound".

	Applied to Inorganic Reinforced Cement Board+
Flame spread	10
Smoke developed	5

⁺Tested as applied in three 3/8in. beads 5 in. OC, Covering 6.3 percent of the exposed test sample area.

Sealant material designated Green Glue "NoiseProofing Sealant".

	Applied to Inorganic Reinforced Cement Board+
Flame spread	0
Smoke developed	0

⁺Tested as applied in three 3/8in. beads 5 in. OC, Covering 6.3 percent of the exposed test sample area.

Last Updated on 2010-12-21

Questions? Print this page Notice of Disclaimer Page Top

© 2012 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2012 UL LLC".